



TOWNSHIP OF FERGUSON

3147 Research Drive • State College, Pennsylvania 16801
Telephone: 814-238-4651 • Fax: 814-238-3454
www.twp.ferguson.pa.us

Contract 2018-C20 Park Hills Drainageway Addendum Number 2

This addendum shall be considered a part of the Contract Documents and Specifications for the above referenced project and shall be enforced as if written originally.

1. Contract documents and specifications
 - a. Bid Form:
 - i. Revised to acknowledge Addendum 2
 - b. Supplemental General Conditions – 16. Utility Coordination:
 - i. Added language for additional coordinated work with UAJA. While installing the 36" Concrete Pipe on Devonshire Drive, the contractor shall excavate to expose the sanitary sewer main for a length of 14 feet centered on the storm pipe so UAJA can replace a 10-foot section of their sanitary sewer main. UAJA will perform all work related to replacing their sewer main, including bypass pumping. The contractor will perform all excavation and backfill of the sewer main. Since the sewer main is being replaced, the concrete encasement as depicted on the plans will not be required.

All bidders must use the addendum bid proposal form. Failure to do so will subject the bidder to disqualification.

The date and time for the bid opening remains as Tuesday, October 3, 2023 at 2:00 pm at the Ferguson Township Building.

ISSUED DATE: September 28, 2023
METHOD OF DELIVERY: E-mail to all plan holders with delivery receipt
ISSUED BY: Ronald A. Seybert, Jr., P.E.

ATTACHMENTS:

- Contract documents and specifications revised by Addendum 2 dated September 28, 2023.

Distribute to: All Plan Holders
2018-C20/Contract/Addendum 2